

From: Maher, Nina <Nina.Maher@ottawa.ca>
Date: Mon, Jun 24, 2013 at 10:00 AM
Subject: RE: 17-23 Robinson
To: Chad Rollins <rollinscra@gmail.com>
Cc: "Fleury, Mathieu" <Mathieu.Fleury@ottawa.ca>, ASH Board

Hello Chad,

In your letter, you make reference to the slope of the driveway being 18%. This issue was also noted by the Project Transportation Engineer, who informed the applicant that the underground ramp should be less than 15%. The applicant subsequently provided a revised set of plans which show the new slope of the driveway having a maximum ramp slope of 14.8%.

If you look up the file under 'devapps', you will find a file "Revised Site Plan, Roof Plan, Basement Plan, Sections and Parking" (dated June 2013), where the new ramp slopes are shown.

Regards,

Nina Maher, MCIP, RPP
Planner II, Planning and Growth Management
City of Ottawa
110 Laurier Avenue West, 4th Floor Mail Code 01-14
Ottawa, Ontario K1P 1J1
Phone: (613)580-2424 ext. 29406
Fax: (613)580-2459
nina.maher@ottawa.ca

From: Maher, Nina <Nina.Maher@ottawa.ca>
Date: Fri, Jun 21, 2013 at 2:24 PM
Subject: RE: 17-23 Robinson
To: Chad Rollins <rollinscra@gmail.com>

Hello Chad,

This is to acknowledge receipt of your letter and reference to the new issue raised by your group is included within the Planning Report.

Regards,

Nina Maher, MCIP, RPP
Planner II, Planning and Growth Management
City of Ottawa
110 Laurier Avenue West, 4th Floor Mail Code 01-14
Ottawa, Ontario K1P 1J1
Phone: (613)580-2424 ext. 29406
Fax: (613)580-2459
nina.maher@ottawa.ca